

## Austin, Wanda H

---

**From:** Austin, Wanda H  
**Sent:** Wednesday, May 22, 2013 4:26 PM  
**To:** Enloe Bill (APAC - Harrison) (benloe@wvpaving.com); wncwhitecorp@msn.com; Lenny Hodge; asouthards@sitedevelopmentcorp.com; akeith@nhmconstructors.com; Ron Grigsby (RGrigsby@NHMConstructors.com); Kaleb Stockton  
**Cc:** Alspaugh, Jeffrey E; Austin, Wanda H  
**Subject:** DN00207  
  
**Importance:** High

The proposals were misplaced in our interoffice mail. I apologize for any inconvenience. The proposals have been located and are available for pick up at the Whittier District Office.

Also, a question has been asked about the thickness of the S9.5B lift. The S9.5B should be constructed as one lift of 2" S9.5B. Please disregard any reference to two lifts of 1" each.

Wanda H. Austin, P.E.  
Division 14 Proposals Engineer  
253 Webster Road  
Sylva, NC 28779  
(828) 586-2141

---

Email correspondence to and from this sender is subject to the N.C. Public Records Law and may be disclosed to third parties.